



Product Service

Attestation of Compliance

No. E8N 13 01 50158 040

Holder of Certificate: CREVIS CO., LTD.D-11F, Digital Empire BDG, 980-3
Youngtong-Dong, Youngtong-Gu
Suwon-City, Kyunggi-Do 443-702
REPUBLIC OF KOREA**Name of Object:** Module
(FnIO S-Series EtherCAT Adapter)**Model(s):** NA-9186**Description of Object:**

Rated input voltage:	DC 24 V
System power dissipation:	100 mA
Field power current:	Max. 10 A

Tested according to:

EN 61000-6-2:2005
EN 61000-6-4/A11:2011

This Attestation of Compliance is issued according to the Directive 2004/108/EC relating to electromagnetic compatibility on a voluntary basis. It confirms that the listed apparatus complies with all essential requirements of the EMC directive and applies only to the sample and its technical documentation submitted to TÜV SÜD Product Service GmbH for testing and certification. See also notes overleaf.

Test report no.: CTK-2013-01430**Date,** 2013-01-10 (Kang-Min F.nee)

CE After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 1