



Product Service

EC-Attestation of Conformity

No. E8 05 11 50158 009

Holder of Certificate: CREVIS CO., LTD.
8F Kyung Hee Respia Bd.1024-15
Kyungki-Do
442-470 Youngtong-Dong,Paldal-Gu,Suwon
KOREA

Name of Object: Industrial, Scientific and Medical equipment
Programmable Logic Controller

Model(s): NA-9112, ST-5211, ST-5212, ST-5221, ST-5231,
ST-5232, ST-1114, ST-2124, ST-1124, ST-2114

Description of Object: Rated input voltage: 24 Vd.c. for NA-9112
5 Vd.c. for ST-5211,ST-5212,
ST-5221, ST-5231, ST-5232,
ST-1114, ST-1124, ST-2124,
ST-2114

Tested according to: EN 61000-6-2:2001
EN 61000-6-4:2001

This EC-Attestation of Conformity is issued according to the Directive 89/336/EEC relating to electromagnetic compatibility on a voluntary basis. It confirms that the listed equipment complies with the principal protection requirements of the EMC directive and applies only to the sample and its technical documentation submitted to TÜV Product Service GmbH for testing and certification. See also notes overleaf.

Test report no.: 2005100032



Date, 2005-11-21



After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 1