



# EC-Attestation of Conformity

No. E8 04 02 50158 004

**Holder of Certificate:** CREVIS CO., LTD.

8F Kyung Hee Respia Bd.1024-15  
442-470 Youngtong-Dong,Paldal-Gu,Suwon  
Korea

**Name of Object:** Industrial, Scientific and Medical equipment  
**Programmable Logic Controller**

This EC-Attestation of Conformity is issued according to the Directive 89/336/EEC relating to electromagnetic compatibility on a voluntary basis. It confirms that the listed equipment complies with the principal protection requirements of the EMC directive and applies only to the sample and its technical documentation submitted to TÜV PRODUCT SERVICE GMBH for testing and certification. See also notes overleaf.

**Test report no.:** CTK03-C235



**Date,** 2004-02-18



After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2



**EC-Attestation of Conformity**

No. E8 04 02 50158 004



**Model(s):** NA-9161, ST-7111, ST-3624, ST-3644,  
ST-4622, ST-5101, ST-5111, ST-222F,  
ST-221F, ST-121F and ST-122F

**Description of  
Object:**

NA-9161  
System Power Supply voltage : 24Vdc nominal  
Current for I/O module : Max 5Vdc @ 1.5A  
Field Power Supply Voltage range : 11-28.8Vdc  
ST-7111  
System Power Supply voltage : 24Vdc nominal  
Current for I/O module : Max 5Vdc @ 1.5A  
Field Power Supply Voltage range : 11-28.8Vdc  
ST-3624, ST-3644  
Power dissipation : 200mA maximum @ 5.0Vdc  
Analog Input Range : 0~5Vdc  
ST-4622  
Power dissipation : 250mA maximum @ 5.0Vdc  
Analog Output Range : 0~5Vdc  
ST-5101 and ST-5111  
Power dissipation : 80mA maximum @ 5.0Vdc  
Input Range : 5Vdc(ST-5101) and 24Vdc(ST-5111)  
ST-222F and ST-221F  
Power dissipation : 45mA maximum @ 5.0Vdc  
Digital Output Range : 24Vdc @ 0.3A/ch  
ST-121F and ST-122F  
Power dissipation : 45mA maximum @ 5.0Vdc  
Digital Input Range : 10~28.8Vdc

**Tested  
according to:**

EN 55011:1998+A1:1999,  
EN 61000-6-2:2001