



Product Service

EC-Attestation of Compliance

No. E8N 09 03 50158 030

Holder of Certificate: CREVIS CO., LTD.

D-11F, DIGITAL EMPIRE BLDG, 980-3
YOUNGTONG, SUWON, GYEONGGI-DO 443-813
REPUBLIC OF KOREA

Name of Object: Industrial, Scientific and Medical equipment
FnIO S-Series

Model(s): ST-5444, ST-5422, ST-5642, ST-5114, ST-5112,
ST-5651, ST-5351, ST-3814, ST-5442 and ST-5641

Description of Object: Rated input voltage : 5 Vd.c.
Rated input current : 200 mAmax.

Tested according to: EN 61000-6-2:2005
EN 61000-6-4:2007

This EC-Attestation of Compliance is issued according to the Directive 2004/108/EC relating to electromagnetic compatibility on a voluntary basis. It confirms that the listed apparatus complies with all essential requirements of the EMC directive and applies only to the sample and its technical documentation submitted to TÜV SÜD Product Service GmbH for testing and certification. See also notes overleaf.

Test report no.: 2009030042

[Handwritten signature]

[Handwritten signature]

[Handwritten signature]



Date, 2009-03-18

CE After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.